

DRINKING WATER NOTICE

Monitoring requirements not met for ELIDA VILLAGE

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the First Quarter of 2026 time period we did not monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time: **TOTAL HALOACETIC ACIDS (HAAS)**.

What Should I Do?

This notice is to inform you that ELIDA VILLAGE did not monitor and report results for the presence of the contaminants listed above in the public drinking water system during the First Quarter of 2026 time period, as required by the Ohio Environmental Protection Agency. You do not need to take any actions in response to this notice.

What Is Being Done?

Upon being notified of this violation, the water supply was required to have the drinking water analyzed for the above-mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

Compliance with the MCLs for Disinfection Byproducts (DBPs) is determined based on a Locational Running Annual Average (LRAA). Since this system failed to monitor during the monitoring period referenced in this notice, the LRAA cannot be properly calculated and compliance with the MCL cannot be properly determined. Some people who drink water containing DBPs in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of cancer. If you have specific health concerns, consult your doctor.

A sample was (will be) collected on 2/9/2026.

Sample results and additional information may be obtained by contacting ELIDA VILLAGE at:

Contact Person: Dave Metzger

Phone Number: 419-339-2811

Mailing Address: 406 E Main St

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH0200503 Facility ID:

DS1 Date Distributed: 5/26/2026